

ADVATEK TESTING AND RESEARCH LAB LLP



B-65(D), 1st FLOOR, MAYAPURI INDUSTRIAL AREA, PHASE-1, NEW DELHI-110064, INDIA
Web : www.advancetestinglab.com, Email : advancetestinglab@gmail.com
Tel. : +91-9266-69-9990, +91-9891-35-3939



TEST REPORT

FF : 7.8.1.1

Issued To: M/s. New Sandhya Public Secondary School
Chandu Nagar, Main Karawal Nagar Road
Delhi- 110094
India.

W.O No: ATRL/45/07
Report No: 24082907
Date of Issue: 04-09-2024
Date of Receipt: 29-08-2024
Party Ref. No: PV & Verbal Dated 29-08-2024
Order Confirmation Date: 29-08-2024

SAMPLE PARTICULARS

PAGE 1 OF 1

1. **Sample Packaging:** In Plastic bottle.
2. **Sample Quantity:** Approx 1 litre.
3. **Sample Description:** One sample described by party as Water for Drinking purpose, was received for following tests only.

TESTS RESULTS

S.NO	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS:10500-2012)	CONFORMITY
1	Odour	IS:3025 (PART 5)-18 RA: 2022	Agreeable	Agreeable	YES
2	Taste	IS:3025 (PART 7)-17 RA: 2022	Agreeable	Agreeable	YES
3	Colour, Hazen Units	IS:3025 (PART 4)-21	<5	A. 5 max as acceptable limit B. 15 max as Permissible Limit	YES
4	pH Value	IS:3025 (PART 11)-22	8.0	6.5 to 8.5	YES
5	Total Dissolved Solids, mg/l	IS:3025 (PART 16)-23	114	A. 500 max as acceptable limit B. 2000 max as permissible limit	YES
6	Turbidity, NTU	IS:3025 (PART10)-23	<1	A. 1 max as acceptable limit B. 5 max as permissible limit	YES
7	Chloride as Cl ⁻ , mg/l	IS:3025 (PART 32)-88 RA: 2019	29.7	A. 250 max as acceptable limit B. 1000 max as permissible limit	YES
8	Calcium as Ca, mg/l	IS:3025 (PART 21)-09 RA: 2023	21.6	A. 75 max as acceptable limit B. 200 max as permissible limit	YES
9	Magnesium as Mg, mg/l	IS:3025 (PART 46)-23	1.2	A. 30 max as acceptable limit B. 100 max as permissible limit	YES
10	Total Hardness as CaCO ₃ , mg/l	IS: 3025 (Part 21)-09 RA: 2023	58.8	A. 200 max as acceptable limit B. 600 max as permissible limit	YES
11	Flouride as F ⁻ , mg/l	IS:3025 (PART 60)-23	<0.1	A. 1.0 max as acceptable limit B. 1.5 max as permissible limit	YES
12	Iron as Fe, mg/l	IS:3025 (PART 53)-03 RA: 2023	<0.1	A. 0.3 max as acceptable limit	YES
BACTERIOLOGICAL TESTS					
13	Total Coliform bacteria /100ml	IS: 1622-1981 RA: 2019	Absent	Shall not be detectable in any 100ml sample	YES
14	E.Coli/100ml	IS: 1622-1981 RA: 2019	Absent	Shall not be detectable in any 100ml sample	YES

Remark: The sample confirms to IS: 10500-2012 w.r.t to above tests only.

Authorised Signatory

Civil / Mechanical / Chemical / NDT TESTING

1. The results listed refer only to samples and applicable parameters. 2. Endorsement of product is neither inferred nor implied. 3. Total liability of our lab is limited to the invoiced amount. 4. Samples will be destroyed after 15 days from the date of test certificate unless specified otherwise. 5. Perishable samples will be destroyed in 2 to 7 days as applicable. 6. The Report shall not be reproduced except in full without written approval of Laboratory. 7. Report refers to the sample submitted to us and not drawn by Advatek Testing and Research Lab LLP unless mentioned otherwise. 8. Retesting Charges will be applicable if results are reproducible. 9. Duplicate copy will be issued on chargeable basis. 10. In case of any dispute, the jurisdiction shall be New Delhi Courts.

**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE**

No. DHO/Shah (N)/2024/ **D-338**

Dated: **11/9/24**

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 1040 dated 06.09.2024, the inspection of "NEW SANDHYA PUBLIC SECONDARY SCHOOL" at Chandu Nagar, Main Karawal Nagar Road, Delhi-110094 was carried out on dated 06.09.2024. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

**Manager
NEW SANDHYA PUBLIC SECONDARY SCHOOL
Chandu Nagar, Main Karawal Nagar Road
Delhi-110094**

4
**Dy. Health Officer
Shahdara North Zone**
उप-स्वास्थ्य अधिकारी
शाहदरा उत्तरी क्षेत्र
दिल्ली नगर निगम